

**PERFORMA REGARDING SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE**

No. CHO/05/32

Date: 16.06.2025

It is certified that an inspection team headed Sanjeev Pathore (M.D.) (Name of Officer with designation) from CHO Hardoi (Name of Department/office) inspected the **City Public School** on 16.06.2025 dated found that **City Public School, Bilgram Hardoi Road Uttar Pradesh** (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T. Govt.

The above certificate is valid for One Year

Signature With Seal.....16/06/25
Name:-.....मुख्य चिकित्सा अधिकारी
Designation:-.....CHO
जिला चिकित्सालय हर्दोई

To
City Public School
Bilgram, Hardoi Road Uttar Pradesh
(Name & Address of the Institution)



OFFICE OF EXECUTIVE ENGINEER, CONSTRUCTION DIVISION

U.P. JAL NIGAM, HARDOI

WATER TESTING LABORATORY

CHEMICAL EXAMINATION OF WATER

TEST REPORT

Sources Of Sample.....*Sub. Market Pump*
Date Of Sampling.....*16/07/2025*
Date Of Analysis.....*16/07/2025*
Sample Collected By Sri.....*Pradeep Kumar*

Location Of Source.....*City Public*
Village/Hemlet/Mohalla.....*Sub. Market Hardoi*
Code No.....
Block Town.....
District.....*Hardoi*

SL. NO	Parameters	Quantity (PPM)	BIS. Standard	BIS. Standard	Result
			Desirable Limit mg/L	Permissible Limit in the absence of Alternate Source mg/L	
1	Color (Hazen)	<i>2.07</i>	05	15	
2	Odour	<i>0.50</i>	Agreeable	Agreeable	
3	Taste		Agreeable	Agreeable	
4	pH value	<i>7.07</i>	6.5-8.5	Not Relaxation	
5	Total dissolved solids	<i>309</i>	500	2000	<i>NOTE</i>
6	Chloride (as Cl)	<i>30</i>	250	1000	
7	Fluoride (as F)	<i>0.65</i>	1.0	1.5	<i>All parts of this</i>
8	Iron (Fe)	<i>0.50</i>	0.3	1	<i>in the</i>
9	Nitrate (NO3)	<i>12</i>	45	Not Relaxation	<i>in the</i>
10	Hardness total (as CaCO3)	<i>270</i>	200	600	<i>Second</i>
11	Alkalinity (as CaCO3)	<i>290</i>	200	600	<i>in the</i>
12	Arsenic (as As)		0.01	0.05	<i>as</i>
13	Sulphur (as SO4)		200	400	<i>B/S</i>
14	Turbidity (NTU)	<i>1.4</i>	0.1	0.5	<i>Limit</i>

Tested By

Chemistry Lab assistant

Counter signed

Assistant Engineer (Lab)